

~~MA FILE~~ DDA

OCA 4300-89

21 December 1989

MEMORANDUM FOR THE RECORD

SUBJECT: Results of Asbestos Sampling from the Air Handling Units (AHU) that Service 7D Corridor OHB

REFERENCE: A. Memo for C/SD/OMS/DA fm [redacted] LD/OCA, dtd 8 Nov 89, Subj: Removal of Asbestos

B. Memo to [redacted] LD/OCA fm C/SD/OMS, dtd 15 Nov 89, Subj: Removal of Asbestos, 7D Area, OHB

1. In response to a request from the Office of the DCI, Safety Division collected sections of filters from air handling unit (AHU) #14 that services 7B, 7C & 7D corridors of the Original Headquarters Building (OHB). In addition, filter samples were collected from AHU #12, #13 & #9 which service 6C, 6D & 6E corridors. Recently, these areas underwent renovation which included the removal of asbestos from the hot water pipes.

2. The air filter samples were sent to an EPA accredited laboratory for bulk asbestos analysis. Results of the analysis indicate that no asbestiform minerals were observed in any of the samples. See attached lab results.

[redacted]
Safety Division
Office of Medical Services

cc: D/MS
D/OCA
GC
IG
Counselor to the DCI
C/OL/FMG/HD

[redacted] OCA

STAT

STAT

STAT

STAT

Page Denied

Next 4 Page(s) In Document Denied